

Controle equivalent daglichtoppervlak

Ambulancezorg Limburg Noord VE67



datum: 24-2-2017

Berekening Ae kozijnen:

Ae;	=	Ad;	Cb;	Cu;	Clta	=	m2	Alpha	Beta
Ae ¹		0,88	0,80	1	1		0,70	20,0	0,0
Ae ²		1,18	0,80	1	1		0,94	20,0	0,0

Controle:

	kozijn	aantal	m2	aanwezig	m2	eis	benodigd	
zitten / eten / keuken VG I								
	Ae ¹ tot.	2	0,70	1,40				
	Ae ² tot.	4	0,94	<u>3,77</u>				
				5,17	74,6	2,50%	1,865	VOLDOET
slaapkamer 1 VG II								
	Ae ² tot.	1	0,70	<u>0,70</u>				
				0,70	10	2,50%	0,25	VOLDOET
slaapkamer 2 VG III								
	Ae ² tot.	1	0,70	<u>0,70</u>				
				0,70	9,7	2,50%	0,24	VOLDOET